



Selection and ordering data



3RH19 21-1DA11
-1JA11



3RH19 21-2DA11
-2JA11



3RH19 21-1EA...
-1KA...



3RH19 21-2EA...
-2KA...

For contactors	Rated operational current NEMA A300 / Q300 ¹⁾	Auxiliary contacts	Screw connection		Cage Clamp connection		Weight approx. kg
		Design NO NC	Order No.	List Price \$	Order No.	List Price \$	
Type							

Laterally mountable auxiliary switch blocks acc. to EN 50 012

Sizes S0 to S12

- First laterally mountable auxiliary switch block (right or left), 2-pole

3RT1 . 2 to 3RT1 . 7	1 1	3RH19 21-1DA11	3RH19 21-2DA11	0.038
----------------------------	-----	----------------	----------------	-------

Sizes S3 to S12

- Second laterally mountable auxiliary switch block (right or left), 2-pole

3RT1 . 4 to 3RT1 . 7	1 1	3RH19 21-1JA11	3RH19 21-2JA11	0.038
----------------------------	-----	----------------	----------------	-------

Laterally mountable auxiliary switch blocks acc. to EN 50 005

Sizes S0 to S12

- First laterally mountable auxiliary switch block (right or left), 2-pole

3RT1 . 2 to 3RT1 . 7	2 - 1 1 - 2	3RH19 21-1EA20 3RH19 21-1EA11 3RH19 21-1EA02	3RH19 21-2EA20 - 3RH19 21-2EA02	0.038
----------------------------	-------------------	--	---------------------------------------	-------

Sizes S3 to S12

- Second laterally mountable auxiliary switch block (right or left), 2-pole

3RT1 . 4 to 3RT1 . 7	2 - 1 1 - 2	3RH19 21-1KA20 3RH19 21-1KA11 3RH19 21-1KA02	3RH19 21-2KA20 - 3RH19 21-2KA02	0.038
----------------------------	-------------------	--	---------------------------------------	-------

EN50005 and EN50012 designate the markings of the auxiliary terminal numbers. For position of the terminals see pages 2/166-169. For int. circuit diagrams see pages 2/156-160.

1) UL ratings, Appendix page 19/7.